



**Bristol Training Facility & Office**  
 2912 River Road  
 Croydon, PA 19021

**Doylestown Training Facility & Office**  
 1760 S. Easton Road  
 Doylestown, PA 18901

**Business (State) Office**  
 275 Swamp Road, Farmhouse 2<sup>nd</sup> Fl  
 Newtown, PA 18940

**Public Safety Degree Office**  
 275 Swamp Road  
 Newtown, PA 18940

## SCBA Inspection Checklist

Equipment assigned to: \_\_\_\_\_ Inspected by: \_\_\_\_\_

Inspection date: \_\_\_\_\_ Inspector's signature: \_\_\_\_\_

SCBA Serial #: \_\_\_\_\_ Date: \_\_\_\_\_

Cylinder DOT #: \_\_\_\_\_ Hydro Date: \_\_\_\_\_

Inspection Procedures	PASS	FAIL
<b>Cylinder:</b>		
1. Check for damage		
2. Current hydrostatic test date		
3. Operational check of the cylinder		
4. Ensure cylinder is full		
<b>Harness &amp; Backpack:</b>		
5. Inspect all straps for damage		
6. Inspect backpack for damage		
7. Inspect all hoses for damage		
8. Operational check of straps and buckles		
<b>SCBA Functional Inspection</b>		
9. Operational check of face piece * (Mask must not show signs of excess heat exposure)		
10. Operational check of regulator and face piece		
11. Operational check of the emergency bypass valve		
12. Operational check of the low pressure warning device		
13. Activates PASS device if part of SCBA unit		
<b>All inspection criteria are in accordance with NFPA 1001, 2013 edition.</b>		

By signing below the person who inspected the SCBA unit, as well as, the Chief or delegated Officer is confirming that this inspection was done and all information is correct. Only SCBA Units that pass this inspection should be used for live fire training. Instructors will have the right to inspect any unit on the day of live fire training, if they feel the SCBA unit being used does not meet this inspection requirement.

All students should be familiar with the SCBA unit they are using for the Live Fire Training as well as having been Fit Tested to the size mask they are to use.

### Review by Instructors Signature:

\_\_\_\_\_  
 Print Signature Date

